

# Attestation

## AgBB

On 28 July 2021, Eurofins Product Testing A/S received a sample of fiber insulation with the product name:

**PYL 2.0 40**

supplied by

**Angel Ruiz Ibañez, S.A.**

The emissions were tested according to AgBB (AgBB - Committee for Health-related Evaluation of Building Products). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 (see the test report no. 392-2021-00380501\_A\_EN).

### **Evaluation of the emission test result according to AgBB:**

---

- Carcinogenic substances were not detectable after 3 and after 28 days.
- The sum of VOC ("TVOC") after 3 days was below the limit of 10 mg/m<sup>3</sup>.
- The sum of VOC ("TVOC") after 28 days was below the limit of 1 mg/m<sup>3</sup>.
- The sum of SVOC after 28 days was below the limit of 0.1 mg/m<sup>3</sup>.
- After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m<sup>3</sup>. This value R was below the limit of 1.
- The sum of VOC without LCI-value after 28 days was below the limit of 0.1 mg/m<sup>3</sup>.
- Formaldehyde after 28 days was below the limit of 0.1 mg/m<sup>3</sup>.

---

**The tested product complies with the requirements of AgBB including the LCI-values (June 2021) for use in the indoor environment.**

24 November 2021



Rasmus Verdier  
Analytical Service Manager



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry